
ROUTE NO.		SECTION	DOUNTY	TOTAL SHEETS	SHEET NO.
S.B.I.				T	
FA.	S20_	01-00282-00-BR	LEE	51	28
	PEG. ROAD DIST. NO. 7			FED. AID PROJECT-	
	S	TRUCTURAL S	HEET 1	4 OF 15	



## MATERIALS FOR ILLINOIS COIL-LOCK ANCHOR BOLT

The anchor boll shall be fabricated from cold drawn or hot finished seamless carbon steel mechanical tubing conforming to ASTM A519, Grade 1026 and supplie with hexagonal nuts and cut washers.

The coil wire shall be made of any suitable soft steel wire.

The finished anchore bolt shall be cleaned of rust and other foreign materials and wrapped or packaged to prevent contamination until they are installed. The epoxy grout shall be a two-component, epoxy resin bonding system conforming to ASTM C881, Type I. Grade I and of a Class suitable for the lemperature at installation.

## INSTALLATION PROCEDURE for the ILLINOIS COIL-LOCK ANCHOR BOLT

- With the coil wire in place, the bolt shall be inserted into the hole and turned clockwise to a snug fit in the hole. Nut and washer shall be placed on the bolt. The nut shall be tensioned until the steel base plates are held securely to the concrete
- Epoxy grout shall be pumped through the zerk fitting with a pressure gun. Pumping shall continue until the expoxy overflows the hole around the bolt shank. After pumping is discontinued, excess epoxy shall be immediately wiped off.

## ALTERNATE ANCHOR BOLTS

The Contractor may use, at his option, the capsule or the adhesive cartridge type anchor rods that have been previously tested and given a prior approval by the Department. The Confractor shall install these anchor rods in pre-drilled holes in accordance with the manufacturer's recommendations and procedures.

The capsule or the adhesive cartridge type anchor rods shall be a two part system composed of:

- A threaded rod stud with nut and washer conforming to ASTM A307.
  A sealed glass capsule or a sealed glass adhesive cartridge containing premeasured amounts of the adhesive chemical.

Holes in the masonry for anchor bolts shall be drilled through the base plates to the diameter and depth shown or in accordance with the manufacturer's recommendation after beams or girders have been erected and adjusted.

Prior to setting the bolts, the holes shall be dry and all dust and loose particles shall be removed by the use of compressed air or vacuuming.

The anchor bolts, furnished, and installed and including the epoxy grout or capsules shall not be paid for separtely but shall be included in the unit bid price for "Elastomeric Bearing Assembly, Type I",